


Stopping Plugs, Metal, Hexagon Socket Head

SP.MA.NPT2.SS.X.25.K05

- Stopping plug for unused cable entries
- Stainless Steel
- Thread NPT 2"
- Without head, installation by means of allen key
- Ex db, Ex eb and Ex tb certified
- Suitable for operation in Zone 1, Zone 2, Zone 21 and Zone 22
- Suitable for operation in Class I, Zone 1/2/22
- Suitable for operation in Class I, Division 2 when installed in accordance with NEC501.10(B)(2)
- Degree of protection IP66 / IP68, UL Type 4X
- Packaging unit: 5 pieces, without accessories



Dimensions



Details see data table

Legend	
1	Stopping plug
KS	Key size
L	Total length
TD	Thread size
TL	Thread length

Technical Data

Mechanical specifications

Thread type	NPT ANSI ASME B1.20.1
Thread size (TD)	NPT 2"
Degree of protection	IP66 / IP68 , UL Type 4X
Material	

Refer to "General Notes Relating to Pepperl+Fuchs Product Information".

Pepperl+Fuchs Group
www.pepperl-fuchs.com

USA: +1 330 486 0002
pa-info@us.pepperl-fuchs.com

Germany: +49 621 776 2222
pa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091
pa-info@sg.pepperl-fuchs.com

PEPPERL+FUCHS

Technical Data

Finish	inherent color silver	
Stopping plug		stainless steel
Mass		
Individual component		approx. 454 g
Packing unit		approx. 2.5 kg
Dimensions		
Thread length (TL)		25 mm
Total length (L)		25 mm
Key size (KS)		14 mm
Tightening torque		
Nut torque at enclosure (SW1)		18 Nm
Ambient conditions		
Ambient temperature		-60 ... 130 °C (-76 ... 266 °F)
Data for application in connection with hazardous areas		
EU-type examination certificate		CESI 15 ATEX 029X
Marking		Ⓔ II 2 GD Ex db IIC Gb Ex eb IIC Gb Ex tb IIIC Db
International approvals		
UL approval		
cULus		E305142 tested to UL 50E and UL 508A CSA C22.2, No. 14-13
IECEx approval		IECEx CES 15.0006X
UKCA approval		CML 22 UKEX 1267X
CCC approval		2021312313000343
Conformity		
Degree of protection		EN 60529
General information		
Delivery quantity		5
Scope of delivery		Stopping Plugs, Metal, Hexagon Socket Head Brief instructions (1 copy)
Supplementary information		EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see www.pepperl-fuchs.com .